

CALL

(08) 8256 0333

POST12 Bishopstone Road
Davoren Park SA 5112**EMAIL**

playford@playford.sa.gov.au

VISITPlayford Civic Centre
10 Playford Boulevard
Elizabeth SA 5112Stretton Centre
307 Peachey Road
Munno Para SA 5115

UNDERGROUND ELECTRICAL CONNECTION APPLICATION FORM

1. Applicant

Title:	Given name:	Family name:
Postal address:		
		Post code:
Phone:	Email:	

2. Property Owner Details

Given name:	Family name:
-------------	--------------

3. Site location details

House Number:	Street:
Suburb:	Post code:

4. Conditions

1. The underground cables shall be laid at a minimum depth of 900 mm below the present or future surface, whichever to be lower (as determined by Council).
2. The underground cables shall be laid from the SA Power Network pole to the frontage of the property at 90 degrees to the road alignment.
3. Cables shall be laid in accordance with the Australian Standard 3000 1981 (SAA Wiring Rules), and the SA Power Network Service Requirements.
4. The trench shall be backfilled and compacted in layers not exceeding 300 mm in depth.
5. The Contractor shall erect signs, barricades and lights to the satisfaction of Council, adjacent to the excavation.
6. The Council shall not accept responsibility for any damages or claims resulting from the laying of the service.
7. No responsibility will be accepted by the Council for any damage to the service from any causes whatsoever.
8. Any future alterations necessary through road widening or other works shall be carried out at no cost to the Council.
9. The service shall remain during the pleasure of the Council.

10. The certification on the front of this application is to be completed and forwarded to Council within seven (7) days of the work being carried out.

Prior to submitting this application, an electrician shall contact SA Power Networks, Telstra and Origin Energy to ascertain location of underground plant and any special precautions necessary

PLAN REQUIREMENTS:

A sketch at a scale of approximately 1:500 metres shall be drawn in the space provided showing:

- (a) Front boundary of the property, and location of side boundaries.
- (b) Position of SA Power Network pole.
- (c) Precise location of cable showing measurements.
- (d) Direction of North

Draw a plan in space provided showing the cable layout between pole and boundary only including measurements

5. Applicant Declaration

I hereby certify that the conditions required by this approval notice have been fully complied with.

Name (Electrician)	Signature	Date
--------------------	-----------	------

6. City of Playford Approval

Approved:

Date: