



NOTES:

1. FOR USE ON PIPE AT GRADES OF 1 IN 5 OR GREATER.
2. TO BE CONSTRUCTED AT A MIN EVERY 5TH JOINT AND AT ALL STRUCTURES.
3. CONCRETE STRENGTH TO BE 25MPa.
4. RRJ PIPES TO BE USED.

ALL MEASUREMENTS IN MILLIMETRES

						INFRASTRUCTURE GUIDELINES (SA)			
						SHEET TITLE			
						STORMWATER DRAINAGE PIPE ANCHOR BLOCK			
						SCALE		NTS @ A3	
						DRAWING No.		REV	
						SD 400		B	
B	ISSUED FOR REVIEW		10.05.2016	JZ	DL	DSL			
A	ISSUED FOR REVIEW		15.03.2016	JZ	DL	DSL			
REV	DESCRIPTION		DATE	DES	DRW	APP			
THIS PROJECT HAS BEEN ASSISTED BY THE LOCAL GOVERNMENT RESEARCH AND DEVELOPMENT SCHEME AND INSTITUTE OF PUBLIC WORKS ENGINEERING AUSTRALASIA									